



April 13, 2010

POLYLOK INC./ZABEL
PETER GAVIN
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: POLYLOK INC./ZABEL
Product Name: **PUMP, FILTER OR SUMP BASIN**
Model Number(s): **24 IN. DIA. BASIN**
(1.95 GALS./IN., AVAILABLE IN HEIGHTS 38 THROUGH 62 INCHES IN 6-INCH INCREMENTS)
Product File No: 20100145

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of AUGUST 2015.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- **Additional information is included as attachment(s) to this letter; see attachment A and B.**

This approval supersedes the approval issued on 7/22/2005 under product file number 20050596.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050596.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Review
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@WI.GOV